



GYPSUM ASSOCIATION

810 FIRST STREET NE, #510 WASHINGTON, DC 20002

SHEAR VALUES FOR SCREW APPLICATION OF GYPSUM BOARD ON WALLS (GA-229-96)

A series of tests was conducted in accordance with ASTM E 72 to determine the shear resistance of gypsum board applied to one side of wood stud partitions 16" o.c. using Type S or W screws at different spacings. Parallel and perpendicular applications, with horizontal joint unblocked, were evaluated. The results are summarized below. These values represent average ultimate shear. Appropriate safety factors should be considered for design use.

Board Thickness	Direction of Application	Screw Type	Edge Screw Spacing	Field Screw Spacing	Average Ultimate Shear/lin.ft.	Test Report Number/Date*
½	Parallel	1¼" W #6	4" o.c.	16" o.c.	485 lbs	WHI-651-0253.02, Test A; 8/1/88 & 8/2/88
† ½	Parallel	1¼" W #6	4" o.c.	12" o.c.	472 lbs	WHI-651-0253.02, Test C; 8/1/88 & 8/2/88
½	Parallel	1¼" W #6	8" o.c.	12" o.c.	215 lbs	RAD-551, 9/85
½	Perpendicular	1¼" W #6	8" o.c.	12" o.c.	184 lbs	RAD-552, 9/85
‡ ½	Parallel	1¼" S #6	8" o.c.	12" o.c.	225 lbs	RAD-555, 9/85
‡ ½	Parallel	1¼" W #6	6" o.c.	12" o.c.	269 lbs	RAD-555, 9/85
‡ ½	Parallel	1¼" W #6	12" o.c.	12" o.c.	169 lbs	RAD-555, 9/85
⁵⁄₈	Parallel	1¼" W #6	8" o.c.	12" o.c.	281 lbs	RAD-553, 9/85
⁵⁄₈	Perpendicular	1¼" W #6	8" o.c.	12" o.c.	215 lbs	RAD-554, 9/85

* = WHI - Inchcape Testing Services/Warnock Hersey
 RAD - Resources Applications, Designs, and Controls, Inc. (RADCO)
 † = Studs spaced 24" o.c.
 ‡ = Check test, only one specimen tested.

The following conclusions can be drawn from these tests:

All other conditions being equal,

1. Shear values are comparable for both Type S and W screws,
2. Shear values for parallel application exceed those for perpendicular application,
3. Shear values for ⁵⁄₈" gypsum board exceed those for ½" gypsum board,
4. Shear values increase with closer spacing of perimeter fasteners, and
5. When compared to other shear test results, shear values for screws are higher than for nails.

MEMBER COMPANY LIST

2001

AMERICAN GYPSUM

BPB AMERICA, INC

CONTINENTAL GYPSUM COMPANY

G-P GYPSUM CORPORATION

JAMES HARDIE GYPSUM

LAFARGE GYPSUM

NATIONAL GYPSUM COMPANY

PABCO GYPSUM

A Division of Pacific Coast Building Products, Inc.

TEMPLE-INLAND FOREST PRODUCTS CORPORATION

UNITED STATES GYPSUM COMPANY

WESTROC INC.



GYPSUM ASSOCIATION

810 First Street NE, #510

Washington, DC 20002

202-289-5440

Fax: 202-289-3707

www.gypsum.org